

OPAQUE ABOVE-GRADE WALL - THERMAL ENVELOPE REQUIREMENTS

		Energy Code	2012 SEC		2012 WSEC		2014 OEESC		2012 IECC			
		Climate Zone	5 and Marine 4		5, 6 and Marine 4		5 and Marine 4		5 and Marine 4		6	
Guide Assembly #	Classification	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	
8A 8B	Wood-Framed Wall with Adhered Masonry Veneer	Wood-Framed and Other	R-13 + R-7.5ci	R-21 int	R-21 int	R-21 int	R-13 + R-3.8ci or R-21	R-13 + R-3.8ci or R-21	R-13 + R-3.8ci or R-20	R-13 + R-7.5ci or R-20 + R-3.8ci	R-13 + R-7.5ci or R-20 + R-3.8ci	R-13 + R-7.5ci or R-20 + R-3.8ci
			<i>U-0.051</i> <i>(R-19.6)</i>	<i>U-0.054</i> <i>(R-18.5)</i>	<i>U-0.054</i> <i>(R-18.5)</i>	<i>U-0.054</i> <i>(R-18.5)</i>	<i>U-0.064</i> <i>(R-15.6)</i>	<i>U-0.064</i> <i>(R-15.6)</i>	<i>U-0.064</i> <i>(R-15.6)</i>	<i>U-0.064</i> <i>(R-15.6)</i>	<i>U-0.051</i> <i>(R-19.6)</i>	<i>U-0.051</i> <i>(R-19.6)</i>